



Microbac Laboratories, Inc., New York Division  
**CERTIFICATE OF ANALYSIS**

J1B0694

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Goardino 3

Fred Hauck  
 20104 NYS Route 3  
 Watertown, NY 13601

Project / PO Number: N/A  
 Received: 02/09/2021  
 Reported: 02/23/2021

**Analytical Testing Parameters**

<b>Client Sample ID:</b> 58									
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> Client				
<b>Lab Sample ID:</b> J1B0694-01					<b>Collection Date:</b> 01/29/2021 8:05				

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0021	0.015 AL	0.0010	mg/L		02/19/21 1009	02/19/21 1132	DLO

<b>Client Sample ID:</b> 18								
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> Client			
<b>Lab Sample ID:</b> J1B0694-02					<b>Collection Date:</b> 01/29/2021 7:54			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0268	0.015 AL	0.0010	mg/L		02/19/21 1009	02/19/21 1137	DLO

<b>Client Sample ID:</b> 59								
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> Client			
<b>Lab Sample ID:</b> J1B0694-03					<b>Collection Date:</b> 01/29/2021 7:59			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0137	0.015 AL	0.0010	mg/L		02/19/21 1009	02/19/21 1139	DLO

<b>Client Sample ID:</b> 25								
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> Client			
<b>Lab Sample ID:</b> J1B0694-04					<b>Collection Date:</b> 01/29/2021 7:56			

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0015	0.015 AL	0.0010	mg/L		02/19/21 1009	02/19/21 1141	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1B0694

<b>Client Sample ID:</b> 22	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J1B0694-05		<b>Collection Date:</b> 01/29/2021 7:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0048	0.015 AL	0.0010	mg/L		02/19/21 1009	02/19/21 1143	DLO

<b>Client Sample ID:</b> 55	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J1B0694-06		<b>Collection Date:</b> 01/29/2021 8:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0276</b>	0.015 AL	0.0010	mg/L		02/19/21 1009	02/19/21 1145	DLO

<b>Client Sample ID:</b> 19	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J1B0694-07		<b>Collection Date:</b> 01/29/2021 7:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0041	0.015 AL	0.0010	mg/L		02/19/21 1009	02/19/21 1148	DLO

<b>Client Sample ID:</b> 32	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J1B0694-08		<b>Collection Date:</b> 01/29/2021 7:57

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.564</b>	0.015 AL	0.0010	mg/L		02/19/21 1009	02/19/21 1150	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J1B0694

Client Sample ID: 37	Collected By: Client
Sample Matrix: Drinking Water	Collection Date: 01/29/2021 7:58
Lab Sample ID: J1B0694-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.015 AL	0.0010	mg/L		02/19/21 1009	02/19/21 1152	DLO

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Sara Lechleitner  
Customer Relationship Coordinator  
Reported: 02/23/2021 14:13

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

3821 Buck Drive  
 Cortland NY 13045  
 Phone: (607)753-3403 Fax: (607)753-3415  
 NY #10795, EPA #NY00935

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on ice  
 MNY Workorder #

*Guardino 3*

**Client Information**  
 Name: Jeff Lew Boces  
 Address: 20104 NYS Route 3  
 Contact: Health/Safety Dept.  
 Phone: 315-779-7000  
 Project: Lead Testing  
 Quote ID: PO#  
 Rush TAT Bus. Days: 2-5 5-7 7-10  
 Carbon Copy: Yes

**Billing/Invoice:**  
 Email Results: Yes  
 Fax Results: Yes

**Sample Information**  
 Description/Location: Total Lead (EPA 200.8)  
 Date: 1/29/01  
 Time: 8:05  
 Matrix Type: DW

Number	Sample Information		Analysis Requested		Number of Containers for Analysis Requested	Comments
	Description/Location	Date	Time	Matrix Type		
1	58	1/29/01	8:05	DW	1	
2	18		7:54			
3	59		7:59			
4	25		7:56			
5	22		7:55			
6	35		8:03			
7	19		7:50			
8	32		7:51			
9	37		7:58			
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

**Receiving Info (Lab Use Only)**  
 Ice: YES NO  
 Cooler: YES NO  
 Sample Temp: YES NO  
 Cooler Seal: YES NO  
 Pickup: YES NO  
 Dropoff: C W  
 Accepted?  
 Container Material  
 Container Size  
 Preservative

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE  
 PM: Shannon Weeks

156  
 2-5-01  
 1/29/01 10:56  
 2/5/01 14:57  
 34:50

**Print Name and Company**  
 Sampled: [Signature]  
 Received: [Signature]  
 Received: [Signature]

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will substitute the analysis to another accredited laboratory. By signing this document you are certifying that you have been informed by MNY of the intent to substitute and are in agreement with this action.